



Karnataka Fire and Emergency Services Department

Office of the Chief fire officer,
Bangalore west zone, High-ground fire station premises,
Sheshadri road, Bangalore – 560 009.
080 – 22971523 / 500 / 600. Fax : 080 – 22971523.



No.24/CFO/BWZ/2021

-01-2021

To,

*The Chairman,
Yashasvi Vidyanikethan,
No. 1/2, Bagalur Road,
Kattigenahalli, Bengaluru .*

Sir,

Sub : Issue of 'Fire safety Recommendation' to *Yashasvi Vidyanikethan*
at *No. 1/2, Bagalur Road, Kattigenahalli, Bengaluru.*

Ref: Your letter Dated 07-01-2021.

*** **


With reference to the subject above cited, the premises of *Yashasvi Vidyanikethan* situated at *No. 1/2, Bagalur Road, Kattigenahalli, Bengaluru* was inspected by District Fire Officer, Yelahanka Fire Station on 13-01-2021 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under;

ANNEXURE-B

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.
(These condition are indicative and not exclusive all relevant provisions related to
fire and life safety of NBC 2016 are mandatory.)

A. Details of the building / premises :-

01.	Name and Address of the Applicant.	:	<i>The Chairman, Yashasvi Vidyanikethan, No. 1/2, Bagalur Road, Kattigenahalli, Bengaluru .</i>
02.	Name and Address of the premises.	:	<i>Yashasvi Vidyanikethan, No. 1/2, Bagalur Road, Kattigenahalli, Bengaluru .</i>


CHAIRMAN
YASHASVI VIDYANIKETHAN
1/2, Bagalur Road, Kattigenahalli,
Bengaluru - 560 063


PRINCIPAL
YASHASVI VIDYANIKETHAN
1/2, Bagalur Road, Kattigenahalli,
Bengaluru - 560 063.



03.	Name & address of the building owner	:	<i>The Chairman, Sri G. Lakshmaiah Educational Trust, Yashasvi Vidyanikethan, No. 1/2, Bagalur Road, Kattigenahalli, Bengaluru .</i>
04.	Number of buildings	:	One building.
05.	Number of floors	:	Ground and 2 upper floors
06.	<u>Floor-wise details of occupancy:-</u>		
	Ground floor	:	Office, principal & chairman chamber, AV room, sports room, activity room & 8 class rooms.
	1 st floor	:	Staff room, meditation room, library 13 class rooms.
	2 nd floor	:	Computer lab, maths lab, AV room, composite science lab & 7 class rooms.
07.	Height of the building	:	10.00 mtrs.
08.	Site area	:	4251.21Sq. mtrs
09.	<u>Built-up area of each floor:-</u>		
	Ground floor	:	1016.96 Sq. mtrs
	1 st floor	:	1016.96 Sq. mtrs
	2 nd floor	:	1016.96 Sq. mtrs
10.	Total built-up area	:	3050.88 Sq. Mtrs.
11.	<u>Surrounding properties:-</u>		
	East	:	B+G+5 upper floor building
	West	:	B+G+5 upper floor building
	North	:	24.00 mtrs wide Bagaluru to NH 7 main road
	South	:	Vacant sites
12.	<u>Open space all around the building:-</u>		
	East	:	02.90 mtrs
	West	:	02.00 mtrs
	North	:	Min 10.00 mtrs
	South	:	03.20 mtrs
Allowed setbacks (open space) should be maintained free from further obstruction / construction			

CHAIRMAN
YASHASVI VIDYANIKETHAN
1/2, Bagalur Road, Kattigenahalli,
Bengaluru - 560 063


PRINCIPAL
YASHASVI VIDYANIKETHAN
1/2, Bagalur Road, Kattigenahalli,
Bengaluru - 560 063.



B. On inspection of this School premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)			Recommendations (04)
01.	Accessibility to the Premises	The premises is accessible from 24.00 mtrs wide Bagaluru main road located on Northern side and hard enough to carry the weight of water tender.			Adequate
02.	Number of entrances	One entry of 04.60 mtrs width located on Southern side.			Not complied One entry of 06.00 mtrs width should be provided for easy movement of emergency vehicles.
03.	Diesel generator	Not provided			One Adequate capacity of generator should be provided and it should be connected to alternative power supply.
04.	Number of staircase	Nos. of staircases	:	02 nos (1 spiral metal)	Complied
		Width of staircases	:	01.50 mtrs & 0.80 mtrs	
		Width of treads	:	30 Cms	
		Height of risers	:	15 Cms	
		Nos. of riser per flight	:	10 Nos'	
		Height of handrails	:	0.80 mtrs	
		Head room clearance	:	Min 02.80 mtrs	
05.	Portable extinguishers	08 ABC type fire extinguishers, each of 2 kgs capacity has been provided.			In-additional to the existing fire extinguishers A. One water mist extinguisher of 9 ltrs capacity should kept near each staircase landing.


CHAIRMAN
 YASHASVI VIDYANIKETHAN
 1/2, Bagalur Road, Kattigenahalli,
 Bengaluru - 560 063


PRINCIPAL
 YASHASVI VIDYANIKETHAN
 1/2, Bagalur Road, Kattigenahalli,
 Bengaluru - 560 063.



			<p>B. One mechanical foam extinguisher of 9 ltrs capacity & One ABC type extinguisher of 6 kgs capacity should be provided near diesel generator.</p> <p>C. One CO2 type fire extinguisher, of 4.5 kgs capacity should be provided near each electrical panel board & electrical room.</p> <p>D. One ABC type fire extinguisher of 06 kgs capacity should be provided for every 100 should be provided.</p>
06.	Hose reel hose system	Not provided	<p>02 Hose Reel Hose near the each staircase (one for every 1000 Sq. mtrs). each hose reel hose of min 19 mm size and of adequate length to reach the farthest point of each floor should be provided shut off branch having a nozzle of 5mm size. The hose reel hose should be connected at each landing.</p>
07.	Terrace tank over respective tower terrace.	Not provided	<p>Each system should be connected to an over head tank of 10,000 ltrs capacity.</p>


CHAIRMAN
 YASHASVI VIDYANIKETHAN
 1/2, Bagalur Road, Kattigenahalli,
 Bengaluru - 560 063


PRINCIPAL
 YASHASVI VIDYANIKETHAN
 1/2, Bagalur Road, Kattigenahalli,
 Bengaluru - 560 063.



08.	At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	Not provided	Each system should be connected to an booster pump of 450 LPM. Further the system should be connected to an alternative source of power supply.
09.	Escape routes	Direction in which the students have to move in the event of an emergency has been displayed in the corridor on each floor during evacuation.	Complied
10.	Fire order (Fire safety plans)	Not displayed	A notice board Have been indicated the action should be taken by the employees in case of any emergency should be displayed with the telephone number of Yelahanka fire station i.e 080 - 29733407 & 101, 550, 500 & 600 and the telephone number of nearest ambulance service & Police station.
11.	No smoking board	Not displayed	COTPA Sec-4 directin No Smoking area smoking here is an offence board should be written in English & Kannada both language shall be prominently displayed at inside the entry / exit of the each floor.
12.	Fire fighting training	Not imparted	At-least 40% of the staff should be got trained in basic fire fighting at R.A. Mundkur Fire and Emergency Services Academy, Bannerughatta road, Bangalore

CHAIRMAN
YASHASVI VIDYANIKETHAN
1/2, Bagalur Road, Kattigenahalli,
Bengaluru - 560 063

PRINCIPAL
YASHASVI VIDYANIKETHAN
1/2, Bagalur Road, Kattigenahalli,
Bengaluru - 560 063




13. **Fire precautionary measures :-**
- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.
 - Accumulation of combustible waste in and around the premises should be avoided.
 - The exit ways shall be always kept clear without any obstruction.
 - Liquefied petroleum gas should not be stored in the building.
 - The doors shall not be kept locked / latched during working hours and shall be free from obstruction.
 - During the class hours the class room doors shall not be locked from inside to out side.
 - As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department.


Under the above circumstance the Karnataka Fire & Emergency Service Department is issuing '**Fire Safety Recommendation**' to ***Yashasvi Vidyanikethan*** situated at ***No. 1/2, Bagalur Road, Kattigenahalli, Bengaluru*** subject to condition and compliance of the above recommendations in column -4 of serial - B within 3 months and compliance to the undersigned.


This **Fire Safety Recommendation** is valid for only one year from the date of issue and it is renewable.

♣ **All requirements recommended above are as per National Building Code- 2016 Part-4 clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.**

Yours faithfully


Chief Fire Officer
 Bangalore West Sub Station Road,
 Highground Fire Station Premises,
 Bangalore - 560 009.


CHAIRMAN
YASHASVI VIDYANIKETHAN
 1/2, Bagalur Road, Kattigenahalli,
 Bengaluru - 560 063


PRINCIPAL
YASHASVI VIDYANIKETHAN
 1/2, Bagalur Road, Kattigenahalli,
 Bengaluru - 560 063.